



OFFICE OF THE  
CHIEF

109 Chestnut Street  
North Syracuse, N.Y. 13212  
(315) 458-1920

## North Syracuse Volunteer Fire Department

**RECEIVED**

**JAN 06 2023**

Village of North Syracuse

TO: Codes Department

FROM: Patrick Brennan *PB*  
Chief of Fire

RE: Site Plan for proposed restaurant  
5357 West Taft Road

DATE: January 4, 2023

I am in receipt of drawings provided by Napierala Consulting dated November 29, 2022, for the above captioned address provided by Amy Franco yesterday. I have reviewed Layout Plan C-3.

At this time, the Fire Department has no issues with the Site Plan as submitted. If an automatic sprinkler system is required, we would request that the FDC, fire alarm panel and lock box all be located adjacent to the main entrance of the restaurant.

Please feel free to contact Paul Linnertz or me at any time if there are updates or if additional clarification is required.