



OFFICE OF THE
CHIEF

109 Chestnut Street
North Syracuse, N.Y. 13212
(315) 458-1920

North Syracuse Volunteer Fire Department

TO: Greg Lancet, Chairman, Planning Board
Codes Office ✓

CC: Amy Fanco, CHA
Gregory Sgromo, Dunn & Sgromo Engineers

From: Pat Brennan, Chief *PSB/EB*

Re: Site Plan review
445-447 South Main Street

RECEIVED

FEB 02 2023

Village of North Syracuse

Date: January 31, 2023

I am in receipt of documentation submitted by Mr. Sgromo dated January 9, 2023, for the above captioned location. I must bring to your attention an error at the bottom of page 2 of the submittal, "The building has a current fire sprinkler system ...". This statement is incorrect. The building is not protected by an automatic sprinkler system. I walked through the building again today to be sure.

The section "Public Utilities" found on page 4, indicates the current water supply is adequate for their intended purpose. If the Building Code requires an automatic sprinkler system a separate fire service main may be required.

At this time the Fire Department has no issue with the unsigned site plan, as depicted in the sheet labeled SP-1, dated January 6, 2023, as provided by Gregory Sgromo.

The Department requests that the following items be located within the immediate area of the main entrance: Fire Department Connection, a SUPRA lock box and the fire alarm panel.

Thank you for the opportunity to review this proposed project on behalf of the Fire Department.