

Village of North Syracuse
Department of Public Works
600 S. Bay Road, North Syracuse, NY 13212
315-458-0790

Date: July 1, 2024

Re: 709 N. Main St.: Akina Sushi Syracuse, Inc.

To: Planning Commission Members,

I have reviewed the plans submitted for the above listed project and my findings are as follows:

Looks good; no concerns for DPW.
 Drainage Water Sewer Sidewalks Snow Removal
 Right-of-way Streets/Roads Safety Trash Removal

Concerns: Going from bank to restaurant a lot more people using bathrooms, and kitchen water/
drain use; not sure if the sewers will handle all of that flow.

Did not see anything about a grease trap on the plans and cleanout.

Items I would like the Planning Commission to address:

Drainage Water Sewer Sidewalks Snow Removal
 Right-of-way Streets/Roads Safety Trash Removal

Recommendations:

Based on factors that would affect DPW or its Operations, I recommend the following:

Project does not have any negative impact on DPW or its operations
 They make items noted a part of the conditions for approval
 Project impacts items checked and plan needs to be modified

Sincerely,



Ed Ware
Superintendent of Public Works